

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-RA5006**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### **‘Flame Armour 60 / 90 / 120 / 240’**

**Product:** Fire resisting roller shutter covered by EN 13241

**Intended use:** Fire compartmentation and/or escape routes

Essential characteristics	Performance	Harmonised technical specification
Resistance to Fire <sup>1</sup>	E60 / E90 / E120 / E240	EN 16034: 2014
Smoke control (only for applications where limitation of smoke spread is required)	NPD	
Ability to release <sup>2</sup>	released	
Self Closing (only for self closing fire resistance and/or smoke control doorsets and/or openable windows) <sup>3</sup>	C	
Durability of ability to release	NPD	
Durability of self-closing	NPD	

The following documentation has been used in support of the essential characteristics performance stated above:

1. EXAP referenced WF Report No. 416673 (Issue 3) , Classification referenced WF Report No. 416674 (Issue 4)
2. Test referenced WF Report No. 404452 (Issue 2) and WF Report No. 429933/R (Issue 2)
3. Test referenced WF Report No. 404452 (Issue 2) and WF Report No. 429933/R (Issue 2), Classification referenced WF Report No. 416674 (Issue 4)

## Certificate of Constancy of Performance

**2812-CPR-RA5006**

Placed on the market under the name of

**SSS Industrial Doors Limited  
Red Earth Farm  
Plantation Road  
Turton  
Bolton  
BL7 0DD  
United Kingdom**

and produced in the manufacturing plant.

**E/327**

**This is coded format, and the information is held by the Notified Body.**

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

**EN 16034 : 2014**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **17/11/2020** and reissued on **21/04/2023** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **20/04/2026**

ERO Project Reference: **ERO 034621 P1902**



Paul Duggan  
Certification Manager

CSF408-NL 7.0